



3 ۵۱۵۴۴  
۵۱۵۴۴

No:	TES/2018/W-022		
Project:	Establishing Rainwater Harvesting Facilities in 10 Islands (Ha.Filladhoo, Ha.Maarandhoo, Ha.Muraidhoo, Ha.Uligan, Ha.Utheem, Ha.Molhadhoo, HDh.Finey, HDh.Hirimaradhoo, HDh.Kurinbee and HDh.Neykurandhoo)		
Issued Date	25 <sup>th</sup> April 2018		
No. of Pages: -04	Boq: -00	Drawings: -2	

Please include this amendment when submitting the bid.

No.	Query	Answer
01	<p>Please Clarify following Beneficiary Name? (which one is take as Beneficiary name - Ministry of Environment and Energy or Government of Maldives)</p> <p>Beneficiary Address?</p> <p>All of above details required for obtaining Bank Guarantee (Bid Security) and Credit facilities</p>	<p>Ministry of Finance and Treasury</p> <p>AmeeneeMagu, Male', 20-03</p> <p>Republic of Maldives</p>
02	<p>The couple of places where need to enter total amount and link to summary of BOQ in the Bill Of Quantity has provided the quantity by you as follows, Please clarify</p> <p>I General and Preliminaries – LS – 1.00</p> <p>II Water Supply Conveyance System; - M – 370 III Water Supply Network – M – 640 And..etc</p>	<p>Please disregard the quantities mentioned in the BOQ item summaries (I, II, III, IV....etc). Pricing should be carried for all sub items based on the quantities provided for the respective sub item.</p>
03	<p>Tender documents is silent about details drawings of following</p> <ul style="list-style-type: none"> <li>• Notice Boards</li> <li>• Pipes bedding material (pipe laying details)</li> <li>• Roof Water Harvest Gutters and Down pipes detail</li> <li>• Automated first flush mechanism detail</li> <li>• Recharge Structure detail</li> </ul>	<ul style="list-style-type: none"> <li>• Notice Boards: Please note that BOQ item General and Preliminaries 1.2.7 provides the dimensions of the board Notice board, which should be made from using GI Pipe stands, Canvas printed project details on plywood board.</li> <li>• Pipe bedding Material: Please refer to technical specification chapter 3.3- In most cases class A bedding will be used and material excavates on site can be used after sieving to achieve the specified size.</li> </ul>

		<ul style="list-style-type: none"> <li>• Roof water harvest gutters and down pipe details and first flush mechanics detail provided in Technical specification 1.6.1-B and Drawing No – WS/TYP/04</li> <li>• Recharge Structure details provided with Amendment 3- Ref no: WS/TYP/06</li> </ul>
04	Raw water tank and Clear water tank diameter are different with drawing dimension	<ul style="list-style-type: none"> <li>• Please refer to dimensions provided in WTP layout.</li> <li>• Drawing ref- (island name)/WS/03</li> </ul>
05	Please provide details for construction of brick wall 0.3m height below the boundary wall	<ul style="list-style-type: none"> <li>• Revised Boundary details provided in drawing ref No:WS/TYP/01</li> <li>•</li> </ul>

Please be informed that the deadline for **bid Submission is April 30th, 2018 at 1000hrs** at Ministry of Finance and Treasury, National Tender.


**Name: Ahmed Mujuthaba**


**Signature:**

