



### CLARIFICATION 1

۱ مَحْمُودٌ مُشَوَّرٌ

نمبر	TES/2019/W-102		
نمبر	Construction of R.Vaadhoo Mosque.		
مقدمہ	17 September 2019		
نمبر	نمبر	نمبر	
No. of Pages: -02	Boq: -00	Drawings: -00	

Please include this amendment when submitting the bid. ٢٠٢٤

- Please find the Drawings in AutoCAD Format and BOQ in excel format.
- What is the condition of existing site? Are there any demolishing works or for cutting trees?  
No demolition works but there are some trees which need to be cut down at sight.
- Can we use Manufacture sand for the concrete work?  
Yes
- Can we use MRDC blocks for walls?  
Yes
- Would you please give us more details about both the lands of R.Vaadhoo mosque site?  
How many palm trees and big trees. Please provide us some pictures if you have.  
R. Vaadhoo No Palm trees.
- Also, we would like to know how we get water and electricity to site on both R.Vaadhoo.  
The distance and all.  
Electricity can be taken from the nearest distribution box near the site.
- Is it acceptable to use ground water to mix cement?  
No
- Please clarify the availability of material storage and Accommodation with in the site premises.  
No space for Material storage and Accommodation
- Is there any arrangement to dump construction debris? If so how far proposed location from the construction site.  
All the construction debris should be dumped to the dump yard in islands. Vehicle is required to transport the construction debris to the dump yard.



- Do we want to include Electrical main feeder cable? If yes, give us length?  
Yes, around 100 feet
- Can we use manufacture sand for concrete and masonry work?  
Yes
- Can we use White sand for Block making?  
Yes
- Is there any major demolition works?  
No

محرر

Name: Ahmed Mujuthaba

محرر

Signature:

