




1 نَحْنُ عَرَبٌ شَاوِرٌ

<b>نمبر</b>	<b>TES/2025/W-081</b>	
<b>پراجیکٹ:</b>	<b>Construction of K.Gulhi Mosque</b>	
<b>تاریخ</b>	<b>13<sup>th</sup> July 2025</b>	
<b>پرچہ کی تعداد:</b>	<b>BoQ: -0</b>	<b>نقشہ کشی:</b>
No. of Pages: - 03	BoQ: -0	Drawings: -00

Please include this clarification when submitting the bid.

- **Answers to the Queries are attached with this Clarification.**



مرکز

**Name: Fathimath Rishfa Ahmed**

 $\frac{x}{10}$ 

**Signature:**

Project Name: Construction of K.Gulhi Mosque

Project Number: TES/2025/W-081

#	Query / Question )	Responses / Clarifications / Confirmation / Addendum
1	What is the condition of existing site? Are there any demolishing works or for cutting trees?	There will be no demolition in the current site. Site clearance shall include for clearing roots and stumps for trees smaller than girth 0.6m.
2	Can we get water and electricity for construction work under existing site condition?	No There are no utility connections inside the site, Contractor shall arrange for water and electricity during the work.
3	Is there any space for material storage?	Contractors shall arrange for material storage for the duration of the work if required.
4	Can we use Manufacture sand for the concrete work and other work like masonry and screeding etc...?	All the materials used for concrete shall conform with Architectural Technical Specification Section 3 (. CONCRETE WORKS)
5	Can we use local sand made blocks or equivalent for masonry work?	Material used for masonry and plastering work shall conform to Section 3 - CONCRETE WORKS. Of Architectural Technical Specification
6	Do we need to include Air-conditioning? If yes, please give brand name?	Yes, All the MEP items as per included in the employer requirement shall be included. AC shall be as per MEP technical specification part 4 (4 AIR CONDITIONING & MECHANICAL VENTILATION TECHNICAL SPECIFICATIONS)
7	Is this duty-free project?	No.
8	Can we propose electrical fittings brand?	All the electrical fitting items shall be as per MEP technical specification part 5 (5 ELECTRICAL SYSTEMS TECHNICAL SPECIFICATION)



Project Name: Construction of K.Gulhi Mosque

Project Number: TES/2025/W-081

#	Query / Question )	Responses / Clarifications / Confirmation / Addendum
9	Can we propose bath ware brand?	All the items shall comply with technical specification
10	Do we need to include street feeder cable for this project? From road transformer to building main panel board. , if yes, please give length and size?	No
11	Can you give some reasonable time extension for bid submission?	Bid Submission is extended to 29 <sup>th</sup> July 2025, 13:00:00 hrs Please refer to Addendum 1.
12	The Intended Completion Date is 365 days (section 1.1 (v))	Yes. 365 Days