



**Ministry of Finance And Planning**  
Ameenee Magu, Male', Republic of Maldives  
Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ އޮފް ފައިނަންސް އަންޑް ޕްލާނިންގ  
އަމީނީ މާގު ، މާލެ ، ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ

## CLARIFICATION 1


ފޮތް ބަލާ ސަބަބުން 1

ނަންބަރު No:	TES/2025/W-100	
ޕްރޮޖެކްޓް Project:	Establishment of Quarantine Facility – Kulhudhuffushi Regional Hospital	
އިއްޔަތު Issued Date	21 <sup>st</sup> August 2025	
ސަފުހާގެ އަދަދު No. of Pages: -03	އެ.އެ.އެ. ބޯޅަ BoQ: -00	ޖަހާފައިވާ ޖަހާފައިވާ Drawings: -00

Please include this sheet when submitting the bid

މި ފޮތް ބަލާ ސަބަބުން ފޮތް ބަލާ ސަބަބުން ފޮތް ބަލާ ސަބަބުން

- **Answers for the queries is attached with this Clarification.**



ނަންބަރު

**Name: Fathimath Rishfa Ahmed**

ސަފްދާ

**Signature:**

*[Handwritten Signature]*

## Clarification 1

Ref. No.	Clause of RFB	Queries/Clarification	Response
1	ITT 19.1 Bid Security	The Tender Security shall be in the form of a Bank Guarantee Kindly allow us to submit the Bid Security in the form of Surety Bond (Insurance Bond)	As stated in ITT 19.1 of the Tender Data Sheet, the tender security shall be in the form of a Bank Guarantee.
2	Tender/BOQ	Allow lump sum for provide and maintain a performance guarantee to the value equal to 10% of the contract price from a bank acceptable to the Employer. Please clarify whether Insurance bond from a local reputed insurance company is accepted.	As stated in Clause 4.2 of the Particular Conditions of Contract, the performance security shall be in the form of a Bank Guarantee.
3	Tender/BOQ	Electrical Kindly confirm the point of Supply.	The point of supply is located approximately 100 feet from the site, within the hospital premises. The Contractor shall verify the exact location and requirements on site prior to construction.
4	Tender/BOQ	INDOOR LAMP OUTLET (TWO WAY SWITCH) wiring shall be in 1.5 mm <sup>2</sup> PVC/PVC/Cu cables + 2.5mm <sup>2</sup> E Kindly confirm 3*1.5 sq.mm or 3*2.56 sq.mm cable.	The wiring shall be in 2.5 mm <sup>2</sup> PVC/PVC/Cu cables.
5	Tender/BOQ	FAN OUTLET 1.5mm <sup>2</sup> PVC cable and earth 2.5mm <sup>2</sup> Kindly confirm the wire spec and regulator required.	The wiring shall be 2.5 mm <sup>2</sup> PVC/PVC/Cu cables, with a 2.5 mm <sup>2</sup> earth and regulator is required.
6	Tender/BOQ	FEEDER CABLES 35mm <sup>2</sup> cable 4 core and earth 16mm <sup>2</sup> Cu From MSB To 0-FDB Kindly clarity about cable 4c*35 sq.mm + 1c*16 Sq.mm or 3.5C *35 Sq.mm. Please confirm.	Follow as stated in the BoQ Bill No.04 under electric installations
7	Tender/BOQ	EARTH Supply and install main earths 600x600x3mm copper plates and 25x3mm copper tape, 150mmx50mmx6mm Cu test clamps And Concrete Inspection Gully, enhance material with all accessories, 95mm <sup>2</sup> Cu Earth Cable from MSB to main earth. (Earth resistance less than 05Ω) Quantity given as 1 Items, For outdoor Item like DG, Main panel earthing Quantity need to add. Kindly confirm.	The Panel Earthing is included as one complete item, and the price covers all works required.
8	Tender/BOQ	Plumbing connecting water distrubutin system in the building to the existing water distibution system at the hospital. Kindly provide the additional details about this system.	The connection point to the existing water distribution system is located approximately 100 feet from the site. The connection shall be made to the utility service provider water supply connection.



9	<b>Tender/BOQ</b>	<p>Fire Hose Reel System</p> <p>Connecting fire protection system with existing connection point complete with PRV, isolation valves and other necessary accessories</p> <p>Kindly provide the details about this system.</p>	<p>The Fire Hose Reel System shall be connected to the existing connection point within the hospital premises (approximately 120 feet from the site), complete with PRVs, isolation valves, and necessary accessories. The Contractor shall verify the connection before construction and ensure proper installation in compliance with applicable standards.</p>
10	<b>Tender/BOQ</b>	<p>UPS</p> <p>Kindly confirm whether UPS is required.</p>	<p>If the query refers to providing a UPS for the building, a UPS is not required unless it is specifically stated in the item specifications or elsewhere in the Bidding Documents.</p>
11	<b>General</b>	<p>Fuel</p> <p>Whether fuel shall be provided by client.</p>	<p>If the query refers to fuel for construction works, it is the Contractor's responsibility to arrange all required electricity or fuel during the construction of the building.</p>

