



CLARIFICATION 1

ޞަފްހާ 01

ނަންބަރު No:	TES/2019/W-134		
ފޮތް ޖަހާނީ Project:	Construction of Council New Building at Dh. Kudahuvadhoo		
ބޭރުކޮށްފައިވާ Issued Date	7 th November 2019		
ސަފްހާ ގެ އަދަދު No. of Pages: -2	ބިޔުޕްލާނު BoQ: -00	ޖެޑް ޖެޑް Drawings: -00	

Please include this amendment when submitting the bid. ބިދު ހުށަހަޅާ ފަދަ ފަހަރުގައި މި ޖަހާފައިވާ ޖެޑް ޖެޑް ބޭނުންކުރަންވާނެއެވެ.

Find the following answers with regard to the subjected project.

Please provide details of demolition and cutting of trees?

There are 36 trees to be cut and demolish by the contractor.

2. Is EIA done for this project or do we need to make one by ourselves?

Not necessary.

3. Where to dump construction debris?

It should be taken to the waste management center, if contractor pays, council will provide the service.

4. Can we use local sand for Block making?

Yes

5. Please clarify the availability of material storage and accommodation?

It is available

6. Can we use M-Sand for concrete?

Yes

7. Can we use local sand for block work mortar and plastering?

River sand should be used for Mortar and plastering

8. Can we use ground water for construction?

Yes but the condition of the water should be checked by the contractor and council before use. If it is salty, it cannot be used.

9. Where to get water and electricity?

No supply water available in the island but electricity is available within 200 feet range. (Distribution board is at 200 feet distance)



10. Please provide intended duration and budget of the project?

This should be estimated by the contractor.

11. Rain water collection required or not ?

Not Required

12. Kindly provide the distance from the waste management site?

1 km

13. Elf levelling screeding mentioned in the drawings .it will be expensive than the normal screed. please conform?

Normal screeding is fine

14. Stiffener column reinforcement details not given?

Not required

15. kindly provide the distance from the Electrical main DB?

200 feet

16. Kindly provide the distance from the main sewer?

Nearly 30 feet

17. Which type of sand should be used for plastering?

River sand

18. Which type of materies should be used for Partitions in Office?

Jepson board with SS partition frame

19. Please provide Size of the blocks and which type of sand should be used for making blocks.

It is given in the BOQ

اسم
Name: Ahmed Mujuthaba

اسم
Signature:

