


H06-HIMMAFUSHI



LEGEND:-

SYMBOL	DESCRIPTION	QUANTITY
—	EXISTING Cable	-
---	PROPOSED 35sq.mm Cu/XLPE/SWA/PVC Cable	150m
---	PROPOSED 50sq.mm Cu/XLPE/SWA/PVC Cable	-
---	PROPOSED 70sq.mm Cu/XLPE/SWA/PVC Cable	-
---	PROPOSED 120sq.mm Cu/XLPE/SWA/PVC Cable	-
---	PROPOSED 150sq.mm Cu/XLPE/SWA/PVC Cable	80m
---	PROPOSED 240sq.mm Cu/XLPE/SWA/PVC Cable	-
---	PROPOSED 300sq.mm Cu/XLPE/SWA/PVC Cable	439m
D/B	EXISTING DISTRIBUTION BOX	4
D/B	PROPOSED DISTRIBUTION BOX	-
D/B	EXISTING DISTRIBUTION BOX TO BE REPLACED	3 Nos.
D/B	EXISTING DISTRIBUTION BOX TO BE MODIFIED	1 Nos.

NOTES:-

- THESE DRAWINGS ARE PRELIMINARY AND ARE FOR TENDERING PURPOSES ONLY.
- CONTRACTOR SHALL CARRY OUT DETAILED SITE SURVEY AND ENGINEERING / STUDY TO EVALUATE AND PROPOSE THE EXTENT OF REPLACEMENT / MODIFICATION REQUIRED IN THE EXISTING DISTRIBUTION NETWORK. THIS IS SUBJECT TO REVIEW AND APPROVAL BY THE EMPLOYER DURING THE ENGINEERING PHASE OF THE PROJECT.

	PURPOSE OF SUBMISSION	REV	AUTHORISED BY	DATE	DRAWING TITLE GRID MIDIFICATION DIAGRAM FOR H06–HIMMAFUSHI FOR PV INTEGRATION	DESIGN : PMU	SCALE : N.T.S
						DRAWN : PMU	DRW NO. : H06–J431–HIMMAFUSHI–GR
					PROJECT PREPARING OUTER ISLANDS SUSTAINABLE DEVELOPMENT	LICENCE NO:	ISLAND NAME : HIMMAFUSHI
					CLIENT: GOVERNMENT OF THE REPUBLIC OF MALDIVES	DATE: : 20OCT21	PAGE : 1