



**CLARIFICATION 1**

**1 ވަނަ ސަފްހާ ޖަދުވަލު**

ނަންބަރު No:	TES/2019/W-107		
ޕްރޮޖެކްޓްގެ ނަންބަރު Project:	Design and Build of Ga.Maamendhoo Breakwater Construction.		
ޖުމްލަތެއް Issued Date	11 <sup>th</sup> September 2019		
ސަފްހާތަކާގެ ޖުމްލަތެއް No. of Pages: -03	ބޮޑުވަނަތަކާގެ ޖުމްލަތެއް Boq: -00	ޖަދުވަލުތަކާގެ ޖުމްލަތެއް Drawings: -00	

Please include this clarification when submitting the bid. ބިދު ފޮނުވާނެއިރު މި ޖަދުވަލުގެ ނަންބަރު ބަލައިގެން ފޮނުވަންޖެހެނީ.

- Find attached clarification 1.



ނަންބަރު  
**Name: Fathimath Rishfa Ahmed**

ސަފްހާ  
**Signature:**



## Ministry of Finance

Male', Republic of Maldives

### Design and Build of Ga.Maamendhoo Breakwater Construction.

TES/2019/W-107

## Clarification 01

1. Does the project require the environment monitoring during construction as a part of contractor scope?

Yes. It's the contractor's responsibility.

2. Please specify the mooring block location?

Location will be identified and informed during the construction stage.

3. Is EIA done for this project or do we need to make one by ourselves?

Awarding contractor has to do EIA

4. Where to dump construction debris?

To determine during the EIA stage.

5. Can we use local sand for Block making?

No. It's specified in the employee's requirement

6. Please clarify the availability of material storage and accommodation?

Contractor responsibility for storage and accommodation's before mobilizing.

7. Water supply for construction work source?

Contractor's responsibility to get the necessary permits through FENAKA / council /MWSC. Contractor's responsibility for the supply of water to the site.

8. Method of anchoring of bollards/mooring hooks?

During the detail design stage. Awarding contractor to propose the best method.

9. Existing functions of the harbor?

To access the island and for berthing space for vessels.

10. .the crust level with reference to MSL?

Min requirement specified in the employee's requirement.

11. Is there any bathymetry or any built available of the existing harbour on these?

No

12. Technical specification is not included in the document .or do you expect the contractor to come up with their own specification?

Yes to propose for client to approve.

13. Please clarify the present status of existing breakwater situation or should make total new on?

Sand cement bag totally failed.

14. Clarify if any jetty exist in the site, which should be demolished to build new one? If yes then provide us the length?

No jetty in the construction site.

15. For quay wall and breakwater, you have asked to provide preliminary design calculations? Is it mandatory to provide this as this is only the bidding stage of the project?

Yes, have to provide Preliminary design and design calculations.