



CLARIFICATION 1

1 ވަނަ ޖަވާބު ދޭ ސަފުހާ

ނަންބަރު No:	TES/2022/W-043		
ޕްރޮޖެކްޓް ނަންބަރު Project:	Design and Build of 75 Housing Units at S.Feydhoo		
ޕްރޮޖެކްޓް ދުވަސް Issued Date	26 th April 2022		
ސަފުހާ ގެ އަދަދު No. of Pages: -3	ބީ.ޕީ.ޕީ. BoQ: -00	ޖަވާބު ދޭ ސަފުހާ Drawings: -00	

Please include this Clarification when submitting the bid. ބިދު ހުށަހަޅާ ފަހަރު މި ޖަވާބު ހިމާރުކުރުމަށް އެދިގެން ދެވޭ ނެތެވެ.

➤ Below find the answer for the query

Contractor Comments	Response/Reference Document
<p>1. Clarify the setback required for the project, as this information is missing in the document. We would like to request for the Development guideline drawing, as well as Annex 03 mentioned in the document.</p>	<p>Clarifications are as follows:</p> <ul style="list-style-type: none"> The required setback is 1m from each side of the plot. Annex 03 is written by mistake. Apologies. <p>The amended employer's requirement is attached with this clarification. (Refer to addendum 3)</p>



ނަންބަރު
Name: Aishath Nadheema

ސަފުހާ
Signature: