



CLARIFICATION 2

۲۰ خبر محرم ۱۳۵۰ ۲

نمبر سند No:	TES/2018/W-025		
موضوع Project:	Hdh. Kulhudhuffushi Harbor Expansion Project		
تاریخ Issued Date	9 th September 2018		
نمبر صفحات No. of Pages: -03	نمبر بوک Boq: -00	نمبر نقشہ Drawings: -01	

Please include this clarification when submitting the bid.

- Attached please find:
 1. The clarifications to the queries raised by bidders.(PDF File)
 2. Attachment 1- Presentation .(PDF File)
 3. Attachment 2- Geotechnical Investigation Report .(PDF File)
 4. Attachment 3- 2018. EIA Addendum 1 to Hdh,Kulhudhuffushi .(PDF File)
 5. Attachment 4- 2018-EIA for Harbour expansion works at Hd.Kulhudhuffushi .(PDF File)
 6. Attachment 5- Plate -1 with Bathy .(PDF File)
- Note: Only Bids Submitted by registered companies will be **accepted.**

Please be informed that the deadline for **Bid Submission** is **September 20th, 2018 at 1300hrs** at Ministry of Finance and Treasury, National Tender.

اسم: Aishath Nadheema

Signature:



Attachment of Clarification 2

Sl. No.	Queries Raised	Replies
1.	Please provide Environmental Impact Assessment report for the project	Please refer to the corrigendum. The reports are given for reference purpose only and it is the responsibility of the bidder's to verify the same independently. The client shall not be held responsible for any discrepancies in the data provided.
2.	Please provide Geotechnical report of existing conditions for the project	Please refer to the corrigendum. The reports are given for reference purpose only and it is the responsibility of the bidder's to verify the same independently. The client shall not be held responsible for any discrepancies in the data provided.
3.	Please provide report of Borehole Tests conducted for the project	Please refer to the corrigendum. The reports are given for reference purpose only and it is the responsibility of the bidder's to verify the same independently. The client shall not be held responsible for any discrepancies in the data provided.
4.	Please provide a Bathymetric Survey of recent date for the dredging and construction area	Please refer to the corrigendum. The reports are given for reference purpose only and it is the responsibility of the bidder's to verify the same independently. The client shall not be held responsible for any discrepancies in the data provided.
5.	In Technical Specification Section 1.1 re-dredging of existing harbour is stated. Please provide location, area, drafts, soil conditions, deposit of the dredge material and quantities. Is the re-dredging subject to the same Environmental Management Plan as the new harbour construction?	The re-dredging of existing harbor basin and channel is not envisaged in the present scope of work.
6.	In Environmental Management Plan is stated Contractor shall manage live coral. Please specify quantity of live coral, how to handle the live corals, where to relocate and how to relocate.	The guidelines provided in the EIA report to be followed for management of live corals. Please refer to the corrigendum.
7.	Please specify the deposit area for depositing of dredged material	The map showing the location of onshore dumping ground for dredged material is enclosed. Please refer Corrigendum.



Out

8.	In Technical Specification Section 1.1 it is stated that "The dredging works consists of excavation of coral materials below the existing seabed regardless of nature of the materials encountered during the course of dredging". Please acknowledge the contractor cannot take liability for the nature of existing conditions and remove this paragraph	The harbor basin is required to be dredged to the required levels as mentioned in the drawings. It is the responsibility of the Contractor to achieve the required depths. Please refer to the Geotechnical Investigation Report.
9.	In Technical Specification Section 1.1 e) it is stated that "Unless the engineer directs otherwise all wrecks and other objects encountered during dredging work shall be lifted, removed and disposed of by the contractor without claiming anything extra". Please acknowledge the contractor cannot take liability for the nature of existing conditions and remove this paragraph	The harbor basin is required to be dredged to the required levels as mentioned in the drawings. It is the responsibility of the Contractor to achieve the required depths. Please refer to the Geotechnical Investigation Report.
10.	In Technical Specification Section 1.1 it is stated that "Contractor may need to carryout additional dredging elsewhere, in the event that sufficient fill material is not available within the basin and channel of existing harbour". As these are unforeseen conditions, the contractor cannot take liability for the nature of existing conditions. Please specify where all material for reclamation is to be dredged from.	No additional dredging is envisaged beyond the project area enclosed in the bid document.
11.	In order to comply with the requirement of the methodology of the monitoring program in Environmental Management Plan for the project, please specify limits for all parameters to be tested in table 2.	Please refer to the EIA report issued in corrigendum. The Environmental Protection Agency, Republic of Maldives guidelines shall be followed.
12.	In Environmental Management Plan Table 1 (2.3) it states that "Operation of heavy machinery only in the low tide (dredging and piling works)". Shall this be interpreted as a project requirement?	The point suggests for the potential environmental impacts and mitigation measures. However, it is the responsibility of the bidder to adopt measures in order to mitigate the potential impacts.
13.	In Particular Condition of Contract – Contract Data – Clause 13.5 (b) (ii) 0% is stated as Provisional Sum for Nominated Subcontractors. Please change this to minimum 10%.	No change. The conditions in tender document shall prevail.
14.	The Advance Payment is 15 % and Retention is 5 %. Due to large amount of material procurement from overseas, please change Advance Payment to 30 % and Retention to 0 % or accept payment for material delivered to site.	No change. The conditions in tender document shall prevail.
15.	In order to submit a competitive bid and incorporate answers for our clarifications, we require more time in the tender phase. Please extend the submission deadline for the tender with two weeks.	No change. The conditions in tender document shall prevail.



[Handwritten signature]