



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives

Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ ފިނާންސް
އަމީނީ މާގު ، މާލެ ، ދިވެހިރާއްޖެ

ADDENDUM 1

އަދަދު 1

ނަންބަރު No:	TES/2019/W-171		
ފްރޮޖެކްޓް Project:	Survey, Design and Build of Water Supply and Sewerage Networks in 3 islands (Gdh. Vaadhoo, Gdh. Fiyori and B. Kendhoo) and sewerage network in B.Dharavandhoo		
ދިނުމުގެ Issued Date	8 th January 2020		
ސަފުހާގެ No. of Pages: -01	ބޮޕް Boq: -01	ޖަހާފައިވާ Drawings: -00	

Please include this amendment when submitting the bid. ބިދު ހުށަހަޅާނީ ބަދަލުކުރި ބޮޕް ބޭނުންކޮށްގެންނެވެ.

- Revised BOQ is attached with this Addendum
- Part 2 – Works Requirements – Employer’s Requirements – Part 5 (Last point)**
“Design considerations for treatment plant: Sewage Treatment Plant (STP) should be designed to be installed at a later stage and hence land allocating required for STP should be reserved. The concept and detail design of treatment to secondary level should be included and any proposed technology for treatment plant should be compact. Package treatment plants such as SBR are preferred.”
- The above statement should be revised as follows:**
“Design of sewerage treatment plant: Sewage Treatment Plant (STP) should be designed for installation before end of the project and land allocating required for STP should be identified. The concept and detail design of treatment to secondary level should be included and any proposed technology for treatment plant should be compact. Package treatment plants such as SBR are preferred.”

ނަންބަރު

Name: Aminath Naheen Ahmed

ސަފް

Signature:

