



**Ministry of Finance**

Ameenee Magu, Male', Republic of Maldives

Telephone: 1617, (960) 334 9296

ދިވެހިސަރުކާރުގެ ގެޒެޓް  
ދިވެހިރާއްޖޭގެ ބޭރުގެ ގަވާއިދު

**CLARIFICATION 1**

1 ވަނަ ބަޔާން

No:	TES/2022/ W-001	
Project:	Construction of Building a 2 Story Infrastructure for Dhiffushi Council	
Issued Date	14 <sup>th</sup> February 2022	
No. of Pages: -1	BoQ: -00	Drawings: -01

Please include this amendment when submitting the bid

➤ **Please find the answers of the quarries.**

Question	Answers
1. What is the condition of existing site? Are there any demolishing works or for cutting trees?	• Empty Land / No
2. Can we get water and electricity for construction work under existing site condition?	• Yes
3. Is there any space for material storage?	• Yes
4. Do we need to include street main feeder cable for our scope?	• Yes
5. If yes, what is the distance between electrical MDB and main electricity source point?	• 250 Feet
6. Bathroom fittings chromium finish or plastic finish? Please give brand name?	• Plastic / PVC
7. Can we use Manufacture sand for the concrete work?	• Yes
8. Can we use RDC blocks for walls?	• Yes
9. Please provide the detail drawing for the shoring method?	• Drawing Attached
10. Can you give AC brand name?	• Cannot specify any brand.

AMU



11. Bathroom fittings chromium finish or plastic finish? Please give brand name?	<ul style="list-style-type: none"> <li>Plastic / PVC</li> </ul>
12. Please confirm us for doors quantity in ground floor, because in BOQ, (D2 – 3 nos, D3 – 10 nos) meanwhile in the drawing, it is mentioned as (D2 – 2 nos, D3 – 11 nos).	<ul style="list-style-type: none"> <li>D2 has 3 doors in the BOQ as well as drawing(D2 door count is highlight and photo is attached), D3 as mentioned in Drawing it is 11 doors,</li> </ul>



✍

Name: Fathimath Rishfa Ahmed

✍

Signature:

*[Handwritten signature in blue ink]*