بسم الله الرحمن الرحيم

Ministry of Finance
Ameenee Magu, Male', Republic of Maldives
Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ އޮފް ފިނޭންސް
އަމީނީމަގު ، މާލެ، ދިވެހިރާއްޖެ

CLARIFICATION 2

ކްލެރިފިކޭޝަން 2

ނަންބަރު No:	**TES/2019/W-112**	
ޕްރޮޖެކްޓް Project:	Design and Build of Harbour and Shore Protection in Sh. Lhaimagu	
ތާރީޚް Issued Date	**15th September 2019**	
ޞަފްޙާގެ އަދަދު No. of Pages: -1	ބީ.އޯ.ކިޔު Boq: -00	ޑްރޯއިންގް Drawings: -00

Please include this Clarification when submitting the bid ބީޑް ހުށަހަޅުއްވާއިރު މި ކްލެރިފިކޭޝަން ޑޮކިއުމަންޓާއި އެކު ހުށަހަޅުއްވަން ޖެހިވަޑައިގަންނަވާނެއެވެ.

1. **The TOR is a generic TOR and does not address the specific components of the project, do we follow the TOR, concept drawing or the BOQ?**

   Preliminary concept is part of the TOR. The concepts are communicated with the council and approved. These concepts are the design of the harbor. Only few changes will come to the preliminary design during the detail design stage. Therefore to these concepts the bidder has to give costing via the BOQ given. The client has given the minimum requirement so that the bidder can come up a costing. These are design and build contracts so we encourage all bidders to at least do a field visit so that estimated measurements can be known for bidders own reference when doing the costing.

2. **There is a breakwater to relocate or break, details and drawings of of this breakwater is required for accurate costing.**

   Drawing is attached with this Clarification

3. **Do we have to break the existing quay wall and do a new one? If so please provide drawings and details of this wall.**

   No quaywall have to be demolished. Please refer to the preliminary concept given.

4. **What is the area of reclamation near the revetment?**

   Area of reclamation to be decided from the dredge volume of sand that will be excess after using for back filling and other areas.

ނަން **Name: Fathimath Rishfa Ahmed**	ސޮއި **Signature:**