



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives Telephone: (960) 334 9266, Fax: (960) 332 0706 وبرساغ بر <mark>برا وبرساء</mark> مُوسِودُ ، وُوْ، برفر برادُدُ

CLARIFICATION 1

*ڭۇىرو*ئاھۇش 1

برُسُوْعَهِ No:	TES/2019/W-143		
Project:	Construction of Proposed 12 Classroom Block at S. Maradhoo School		
Ssued Date	12 th November 2019		
ار دُورَدُ دُورَدُ No. of Pages: -02	Boq: -00	نتردر Drawings: -00	

وعَ الرَّوْدُوْرِدُ وَ وَسَوْمُ مَا مِنْ وَمُرْدُورُونُ عَرِيوَ اللَّهِ اللَّهِ اللَّهِ اللَّهِ اللَّهُ اللَّلَّالِي اللَّهُ اللَّ

Find the attached Clarification Sheet

سرير

Name: Aminath Naheen Ahmed

?[₹] Signature:



Republic of Mald

	QUERIES	ANSWERS
1.	Details Required a) Door – D3 Drawing – PVC panel door on PVC frame BOQ – Aluminum panel door on Aluminum frame b) Facia Board Drawing – 35mmx250mm BOQ – 50mmx200mm	Please refer the drawing details
2.	Please clarify the availability of material storage and accommodation with in site premises?	yes
3.	Is there any arrangement to dump construction debris? If so, how far proposed location from the construction site	Yes, 5 minutes by motor bike
4.	Is there any specific restriction or requirement on construction activity	No
5.	Please provide distance from existing main electrical source to the building	10 feet from building
6.	Can we use manufacture sand for concrete and masonry work?	Use M-Sand for concrete and block work mortar.
7.	Can we use White sand for Block making?	Use local sand.
8.	Is there any major demolition work?	Yes, old toilet
9.	Do we want to include Main Panel Board? If yes, please provide the location?	No
10	. Please provide distance from existing sewerage network point to the building	300 feet
11	. Please provide distance from existing water network point to the building	20 feet