

بِسْمِ اللَّهِ الرَّحْمَنِ الرَّحِيمِ

## Information Technology Division

Ministry of Health

ދިވެހިރާއްޖޭގެ ސަރުކާރުގެ ގެޒެޓް  
ދިވެހިރާއްޖޭގެ ސަރުކާރުގެ ގެޒެޓް

### Specification for 3KVA UPS

|                               |  |
|-------------------------------|--|
| DETAILS                       | 3000VA(minimum)<br>WITH AUTOMATIC VOLTAGE REGULATOR  |
| OUTPUT VOLTAGE                | 220V, 230V (nominal), 240V   |
| VOLTAGE DISTORTION FOR OUTPUT | Less than or equal to 5%   |
| OUTPUT CONNECTION QUANTITY    | Eight (4) IEC 320 C13 (Minimum)<br>One(1) IEC 320 C19  |
| INPUT VOLTAGE                 | 230V   |
| INPUT CONNECTION TYPE         | British BS1363A  |
| BATTERY CONDITION             | Leakproof  |
| REPLACEMENT BATTERY COST      | Should include current market price for the replacement battery  |
| INTERFACE PORTS               | One (1) RJ-45 , One(1) Smart slot or equivalent interface port   |
| AUDIBLE ALARM                 | Alarm when on battery<br>Alarm when low battery<br>Alarm when overload   |
| REQUIRED FEATURES             | Surge protection and Noise filtering<br>Include Emergency Power Off feature<br>LED Display with load and Status                                      |
| WARRANTY                      | One-year hardware and TWO years' service warranty<br>One year Guarantee for Battery (provide replacement if battery life ends earlier than one year) |



*Aminath Sakha Saleem*

Aminath Sakha Saleem  
Computer Technician  
21<sup>st</sup> August 2019