





1. ALL DIMENSIONS SHOWN ARE IN MILLIMETERS (MM),
UNLESS OTHERWISE SHOWN
2. ALL LEVELS SHOWN ARE IN METERS,
ALL LEVELS SHOWN ARE FROM MEAN SEA LEVEL
3. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER
RELEVANT DRAWINGS, GENERAL NOTES AND SPECIFICATIONS.
4. ALL NON-PRESSURE PIPES SHALL BE UPVC TO ASTM D-3034
SDR 35.
5. ALL GRAVITY NETWORK LINES SHALL BE 160mm DIA.
6. ALL GRAVITY NETWORK LINES SHALL HAVE MINIMUM 0.5% SLOPE.
7. ALL NON-PRESSURE PIPES SHALL HAVE RUBBER SEAL JOINT.
8. ALL LIFT STATIONS, MANHOLES AND CLEAN OUTS SHALL BE
PLASTIC MOULDED TYPE.
9. CONNECTION FROM THE HOUSEHOLD TO THE INSPECTION
CHAMBER IS OUT OF THIS CONTRACT.
10. PROVISION SHALL BE GIVEN IN IC FOR MULTIPLE CONNECTIONS.
11. THE PIPE DIMENSIONS REPRESENT IN OUTSIDE DIAMETER (O.D).

REFERENCE DRAWINGS									
SL.No.	DRAWING No.			DESCRIPTION					
..
..
..
..
0	15-09-15	DETAILED DESIGN SUBMISSION				JP	SS	MA	
REV.	DATE	DESCRIPTION				DRAWN	CHKD.	APPRD.	
REVISION									
CLIENT  MINISTRY OF ENVIRONMENT & ENERGY REPUBLIC OF MALDIVES									
CONSULTANT: استشاري  مكتب الحبشي للاستشارات الهندسية Al-Habshi Consultants Office Tel.: 2430103 / 2433131 - Fax : 2431136 P.O.Box 27154 Safat 13132 - Kuwait									
PROJECT: Provision of Water Supply Facilities in 04 islands and Sewerage Facilities in 05 islands - R.Hulhudhuffaar Island - Republic of Maldives									
DRAWING TITLE: INSPECTION CHAMBER DETAILS R.HULHUDHUFFAARU ISLAND									
DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE				
SK	JP	SS	MA	AS SHOWN	15-09-'15				
PROJECT No.		SHEET No.		DRAWING No.					
K-619		1 OF 1		RH-SW-104					
REV. No.		0							