



Ministry of Finance and Planning

Ameenee Magu, Male', Republic of Maldives

Telephone: (960) 334 9266, Fax: (960) 332 0706

ދިވެހިރާއްޖޭގެ ފަރާތުން ދަނީ ދަންނަވާ ގޮތުން
އިދާރާތަކުން، ފަންނަ، ދިވެހިރާއްޖޭގެ

CLARIFICATION 1

1 ވަނަ ބަޔާންކުރުމުގެ ތަން

ނަންބަރު No:	TES/2025/W-085		
ދަނީ ބަނޑުވާ ފަރާތުން Project:	Design and Build of Ha.Ihavandhoo Islamic Center		
އުދުހުކުރު ދުވަހު Issued Date	13 th July 2025		
ސަފުހާގެ ޖަދުވަލު No. of Pages: - 03	ބޯޕްރޮޖެކްޓް BoQ: -0	ވަނަ ބަޔާންކުރުމުގެ ތަން Drawings: -00	

Please include this clarification when submitting the bid. ބަޔާންކުރުމުގެ ތަން ދަނީ ބަނޑުވާ ފަރާތުން ދަންނަވާ ގޮތުން.

- **Answers to the Queries are attached with this Clarification.**

ނަންބަރު

Name: Fathimath Rishfa Ahmed

ސަފުހާ

Signature:



Project Name: Design and Build of of Ha.Ihavandhoo Islamic Center

Project Number: TES/2025/W-085

#	Query / Question)	Responses / Clarifications / Confirmation / Addendum
1	rWhat is the condition of existing site? Are there any demolishing works or for cutting trees?	There will be no demolition in the current site. Refer to the scope of work for details for trees on site. Site clearance shall include for clearing roots and stumps for trees smaller than girth 0.6m.
2	Can we get water and electricity for construction work under existing site condition?	No There are no utility connections inside the site, Contractor shall arrange for water and electricity during the work.
3	Is there any space for material storage?	Contractors shall arrange for material storage for the duration of the work if required.
4	Can we use Manufacture sand for the concrete work and other work like masonry and screeding etc...?	All the materials used for concrete shall conform with Architectural Technical Specification Section 3 CONCRETE WORKS)
5	Can we use local sand made blocks or equivalent for masonry work?	Material used for masonry and plastering work shall conform to Section 3 - CONCRETE WORKS. Of Architectural Technical Specification
6	Do we need to include Air-conditioning? If yes, Please give brand name?	Yes all the MEP items as per included in the employer requirement shall be included. AC shall be as per MEP technical specification part 4 (4 AIR CONDITIONING & MECHANICAL VENTILATION TECHNICAL SPECIFICATIONS)
7	Is this duty-free project?	No.
8	Can we propose electrical fittings brand?	All the electrical fitting items shall be as per MEP technical specification part 5 (5 ELECTRICAL SYSTEMS TECHNICAL SPECIFICATION)



Project Name: Design and Build of of Ha.Ihavandhoo Islamic Center

Project Number: TES/2025/W-085

#	Query / Question)	Responses / Clarifications / Confirmation / Addendum
9	Can we propose bath ware brand?	All the items shall comply with technical specification
10	Do we need to include street feeder cable for this project? From road transformer to building main panel board. , if yes, please give length and size?	No
11	As per tender document mosque capacity 700 person? Is this correct?	Yes
12	Can you give solar panel capacity or details?	It is the contractor's scope to design and build the solar system based on the mosque capacity requirements of the mosque and hall, ensuring the system meets the finalized capacity derived from their usage.
13	Can you provide plot dimension?	150 x 150 feet
14	Can you give some reasonable time extension for bid submission?	Bid Submission has been extended to 29 th July 2025, 13:00:00 hrs Please refer to Addendum 2

