تب ما منداز حمن أرحب م



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives Telephone: (960) 334 9266, Fax: (960) 332 0706

وسوع مراد وسرائل وسرائل وسرائل المروس و المراد المروس و المراد المروس و المراد المراد

CLARIFICATION 1

ر و مرور سوسه ا

برُسُونَدِ No:	TES/2019/W - 147	
Project:	Renovation of 3rd Floor of Ghaazee Building	
ار آرین Issued Date	10 th December, 2019	
۱۵. مَرَرُدُ مُرَرُدُ No. of Pages: -01	3v.3.9 BoQ:-00	المراثرين Drawings: - 00

> Find the Responses to the Queries raised.

- Drawing and BoQ PDF file not being able to open the file. Ans: A new PDF file has been uploaded.
- -Kindly provide the floor plan for checking the flooring qty. Ans: Consider the floor area as 6000 square feet.
- Partition for waiting area and printing area qty is not given. Ans: Please refer to page 3 of BoQ and Drawings to get the size of the waiting area. You may use the appropriate quantity to complete the partition of the size given.
- Installation and connection of new Electric and network, kindly provide the drawing.

 Ans: The electrical and network connections are in the drawing on the 4th page of the BoQ and Drawings document (PDF). A new Distribution Box will have to be installed to supply electricity to all the workstations.
- Kindly confirm the network main connection, floor mount socket and new server is required. Ans: The existing server room is on one corner of the floor area (not shown in drawings). There is no floor mounted sockets. All wiring will go through the ceiling and down the poles to the workstations. Sockets will be mounted on the bottom of the workstation partitions. No new server room is required.
- Kindly provide the floor plan, Electric and network drawings in AUTOCAD. Ans: We are not able to provide the drawings in AUTOCAD format.



شرشر

Name: Aiminath Naaheen Ahmed

رِ Signature: