

بِسْمِ اللّٰهِ الرَّحْمٰنِ الرَّحِیْمِ



Ministry of Finance

Male', Republic of Maldives

TES/2022/W-033R01 Construction of Addu City District Court Complex

Contractor Comments	Response/Reference Document
1. What is the condition of existing site? Are there any demolishing works or for cutting trees?	Site has to be cleared of all existing Shrubs and Trees. Trees have to be cut down including 16 (approximate) big trees.No demolition work is included in this scope
2. Can we get water and electricity for construction work under existing site condition?	The contractor shall visit the site for accurate details. Temporary Connection have to made by the Contractor
3. Is there any space for material storage?	The contractor shall visit the site for accurate details. Storage Space will be provided, Contractor can make the storage.
4. Can we use Manufacture sand for the concrete work and other work like masonry and screeding etc...?	The contractor shall follow technical specification. Contractor may use manufacture sand.
5. Can we use local sand made blocks or equivalent for masonry work?	The contractor shall follow technical specification. Contractor should use river sand for blocks and masonry. Local sand should not be used.
6. Do we need to include Air-conditioning? If yes, Please give details	Yes. Details available in drawings and BOQ.
7. Please give details for below connectivity,	1. Electricity - 2. Water Details 3. Sewerage One connection of each to be made.
8. Is this duty free project?	No
9. Do we need to include all furniture?	Contractor has to provide the furniture's mentioned in bill no 16
10. Can we propose AC brand?	It can be proposed. The proposed Brand should correspond to standards specified in Technical specs, drawings and BOQ,
11. Can we propose electrical fittings brand?	It can be proposed. The proposed Brand should correspond to standards specified in Technical specs, drawings and BOQ.

<p>12. Can we propose bath ware brand?</p>	<p>It can be proposed. The proposed Brand should correspond to standards specified in Technical specs, drawings and BOQ,</p>
<p>13. Please provide SLD for all distribution boards.</p> <p>Need comprehensive details for Transformer scope (Capacity, specifications, Drawings, MV cable specifications). Please provide</p> <p>Feeder cables not include in the BOQ. Please provide the cable sizes and lengths.</p> <p>Cable support system not include in the BOQ. Please provide the cable sizes and lengths.</p> <p>Need comprehensive details for Generator scope (Capacity, specifications, Drawings, Cable specifications, Sound level requirement Exhaust System, Requirement of Fuel tank, etc..). Please provide</p>	<p>New Item Included BOQ Ref : 10.2.2. The contractor can assume approx length & cable sizes are available. Cable Tray Already Included BOQ Ref : 10.10.8 no need to include the generator</p>