



- NOTES:-**
- ALL DIMENSIONS ARE IN MILLIMETERS EXCEPT AND OTHERWISE SPECIFIED.
 - CABLE LEGEND AS SHOWN IN DRAWING
 - ALL S/F ELECTRICAL PANELS AND GENERATOR SHALL BE PROVIDED WITH EARTHING SYSTEM
 - ALL ELECTRICAL INSTALLATIONS FOR OUTDOOR USE, SHALL BE PROTECTED FROM RAIN AND DUST
 - ALL PUMPS SHOULD BE PROVIDED WITH OWN CONTROL PANEL WITH NECESSARY PROTECTION
 - ALL EXPOSED INSTALLATION SHOULD BE IN G.I CONDUIT OR SHADED CABLE TRAYS.
 - ALL ABOVE GROUND CONDUIT SHALL BE RIGID HOT DIP GALVANIZED EXCEPT AS NOTED.
 - ALL NEMA 3R GASKETED S.S ENCLOSURES TO HAVE LOCKABLE HANDLE AND 3 POINT LATCHING.
 - EARTH ROD LOCATIONS AND EARTHING CABLE ROUTE SHOWN ARE INDICATIVE ONLY. EXACT ROUTE AND LOCATION SHALL BE DECIDED AT SITE TO SUIT SITE CONDITIONS.
 - THE ENTIRE SITE SHALL BE PROVIDED WITH 70mm² STRANDED BARE COPPER CABLE EARTHING GRID AND 2.4 METER LONG, 16mm DIA EARTH RODS AS SHOWN ON THE DRAWING.
 - THE EARTH TERMINAL INSIDE THE DISTRIBUTION BOARD SHALL BE CONNECTED THROUGH 6mm SQ. CABLE FROM MAIN DISTRIBUTION BOARD AND CONNECTED TO MAIN EARTHING GRID.
 - THE CONNECTION POINT FROM MAIN EARTHING GRID TO BRANCH EARTHING SHALL BE WELDED BY EXOTHERMIC WELDING.

LEGEND:-

	W/P 70W HP SODIUM VAPOUR LAMP
	1 x 40W SURFACE MOUNTED FLUORESCENT LIGHT FITTING
	EXHAUST FAN
	WALL FAN
	D.B W/P FOR LIGHT AND SOCKET
	STARTER PANEL WEATHERPROOF
	EARTH PIT
	13A SWITCHED SOCKET OUTLET
	ISOLATOR / W.T

CABLE LEGEND:-

4c 10mmSQ Armoured Cable + E
3c 2.5mmSQ P/S/P lay in HDG tray
2c 1.5mmSQ P/S/P lay in HDG tray
3c 2.5mmSQ signal layer cable
3c 1.5mmSQ signal layer cable

REFERENCE DRAWINGS

SL.No.	DRAWING No.	DESCRIPTION

..
..
..
..
0	17-09-15	DETAILED DESIGN SUBMISSION	BA	RDS MA
REV.	DATE	DESCRIPTION	DRAWN	CHKD. APPRD.

REVISION

CLIENT
MINISTRY OF ENVIRONMENT & ENERGY
 REPUBLIC OF MALDIVES

CONSULTANT:

Al-Habshi Consultants Office
 Tel : 2430103 / 2433131 - Fax : 2431136
 P.O.Box 27164 Safat 13132 - Kuwait

PROJECT:
 Provision of Water Supply Facilities in 04 islands and
 Sewerage Facilities in 05 islands -
 GA.Kolamaafushi Island - Republic of Maldives

DRAWING TITLE:
**GA.KOLAMAAFUSHI ISLAND
 SEWAGE TREATMENT PLANT
 ELECTRICAL LAYOUT**

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
RDS	BA	RDS	MA	1:50	17-09-15
PROJECT No.	SHEET No.	DRAWING No. KO-EL-110			
K-619	1 OF 1				
REV. No.	0				