

ID	MTH - QUESTIONS TO CLIENT	REFERENCE (CLAUSE, DWG NO, ETC.)	CLIENT / ENGINEER'S RESPONSE
	<u>Harbour works</u>		
1	Do we allow to use rocks in the existing break water at existing harbour.		Existing Breakwater is made of sand cement bags. Therefore, it cannot be used.
2	Please specify the maximum expected dead weight of vessel (DWT) ?	Refer Tender document Section VI Employer's Requirements.- Design criteria	Fishing Vessels: 120 – 150 tons Cargo Vessels: 250 – 300 tons
	<u>Jetty works</u>		
1	Please specify the maximum expected dead weight of vessel (DWT)?	Refer Tender document Section VI Employer's Requirements.- Design criteria	250 – 300 tons

