



CLARIFICATION 2

މަޢުލޫމާތު ބަޔާން 2

ނަންބަރު No:	TES/2023/G-012	
ފޮޓޯ ނަންބަރު Project:	Design, Supply and Installation of Battery Energy Storage Systems and Energy Management Systems in 18 islands across Maldives	
ޖެރީ ކުރި ދުވަހު Issued Date	15 <sup>th</sup> October 2023	
ސަފުޙާ ގެ ޅަންބަރު No. of Pages: -02	ބޯޔު ގެ ޅަންބަރު Boq: -00	ޔަބްލިންގ ގެ ޅަންބަރު Drawings: -00

Please include this clarification when submitting the bid

މި ބަޔާނުގައި ބަޔާންކުރި މައުލޫމާތު ބަޔާން ފޮނުވާނީ ދަންނަވާ ދުވަހުގެ ތެރޭގައި

- Please find attached, answers to the queries received.

ނަންމު  
Name: Aminath Naheen Ahmed

ސަފްޙާ  
Signature:



## CLARIFICATION 2

#	Document Name	Document Reference (Section no/page no etc)	Query	Response
1	Section 6 Employer's Requirements	The PCMS will be fully compatible with existing D-hybrid central SCADA located in Male.	Please clarify whether the existing SCADA system needs to be updated, if so, whether it is within the scope of this contract.	<b>Existing SCADA system does not need updating. But the new systems need to be integrated to the SCADA system.</b>
2	Section 6 Employer's Requirements	A battery room or BESS house needs to be constructed to install the batteries and related equipment. It can be a room/additional building next to the powerhouse where the genset power system is located.	Please clarify there is enough space for battery room or BESS house next to the powerhouse, if not, please provide the distance between BESS house and powerhouse for us to estimate the cable length.	<b>If the existing BESS room is not enough then the contractor is required to build a new BESS room. Space for BESS room will be provided next to the power house, within 50 meters.</b>
3	Section 6 Employer's Requirements	The batteries shall be connected to a dedicated feeder on the main LV distribution board of the powerhouse.	Please confirm the existing main LV distribution board of the powerhouse has suitable dedicated feeder for batteries connection. Please confirm there is no modification on main LV distribution board to be done, and there is no requirement for new low-voltage switchgear.	<b>Feeder will be provided and LV distribution board modification not required under this contract.</b>
4	Section 2: Bid Data Sheet	D. Submission and Opening of Bids, ITB 24.1	By considering the gravity of bid submission document preparation, as well as time requirement for document attestation process, we hereby request from you to extend the bid submission date by another two (02) weeks.	<b>Bid submission date has been already extended. There will be no more extension of bid submission date.</b>

