



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives Telephone: (960) 334 9266, Fax: (960) 332 0706

ADDENDUM 1

1 920 6

سَرُسُوْمَ ر No:	TES/2019/W-131	
00120		
Project:	Design and Build of Jetty and Harbour Upgrade in R.Rasgethem.	
ار آریخ Issued Date	22 nd October 2019	
- وَرُدُّ مُرَدُّ مُرْدُوْ	איי. איי. Boq: -00	تعرفرو Drawings: -01

وَا الْمُعْرِقُورِهُ وِ وَسُوْمُ عَيْمِهُ مُنْ الْمُرَافِدُونَ عَيْمِونَهُ مَا مِوَالْمُونِدُ عَيْمِ وَمُدُونَدُ اللهِ Please include this amendment when submitting the bid . وَمُنْ وَمُونِهُ مُنْ وَمُرَافِدُونَ عَيْمُ وَمُنْ مُؤْمِدُونَ اللهِ اللهِ اللهُ ا

- > Attached please find the revised Harbour Concept for R.Rasgatheem Harbour.
- 1. Do we have to dredge the beaching area?

Please find the attached drawing. That area needs to be reclaimed as shown in the revised concept.

2. Do we have to break existing quay wall? Please let us know the condition of existing quay

Yes, it should be demolished as it is made of sand Cement bags.

3. Do we have to relocate existing breakwater? Please let us know the condition of existing breakwater and what material it is made of, is it failed?

It should be demolished as it is made of sand Cement bags and it is in very poor condition.



سرير

Name: Ahmed Mujuthaba

بدّ

Signature:

R.RASGETHEEMU HARBOUR

