



CLARIFICATION 1

1 ވަނަ ބަޔާން ފޮނުވުމަށް

ނަންބަރު No:	TES/2021/G-015	
ފޮތް ނަންބަރު Project:	Indira Gandhi Memorial Hospital Fire System Replacement Work	
ދީނުވަނަ Issued Date	20 th October 2021	
ސަފުހާ ގެ އަދަދު No. of Pages: -2	ބޯޕްރިޔަންޓް BoQ: -00	ޑްރޯއިންގް Drawings: -00

Please include this Clarification when submitting the bid. ބަޔާން ފޮނުވުމުގެ ތެރޭގައި މި ބަޔާން ހިމަނާލެވިގެން ފޮނުވަންޖެހެނީ.

➤ **Please find below the answers to the queries raised**

QUARIES	RESPONSE
Project Timeline	Project period is 150 days and Gantt chart need to be submitted by the successful vender before commence the project.
a) Working Days / Hours	No specific restriction for the project activities, but work plan need to be adhered for the smooth operation of the hospital. If any difficulties found during the project, it is to be considered upon the management approval.
b) Noise Restriction Days / Hours	Some specific area there that need to be lower noise working site, but alternative days can be given by the approval of management.
c) Can Work each & every floor at same time? If not Scope for work.	It is possible, but if there, any influence for the hospital operation an alternative option can be given soon by prior approval from the hospital management.
Are there any specific rules to follow?	There are no any specific rules that needs to be followed than the MNDF and general rules within the hospital. However, all safety precaution and access procedure need to be followed since begging to end of the project.
Existing fire system need to be removed before new installation or after new installation.	It is not mandatary but it is recommended to remove piece by piece while continuing the new set up.

Is the PA system only for the Fire message purpose or used for Pipe music or nurse calling also?	It is dedicated only for the fire matter only.
For the PA System They have requested Ahuja or Bosch Speakers? How about different brands?	It needs to follow same specification and specially should be with anti-corrosive property at highly sea breeze condition including the warranty
Ceiling Type? (Fixed Ceiling or Removable Ceiling?)	Removable, but any damage during the project need to be fixed.
Is the storage area provided by the client?	Yes
Need a site survey for better understanding the site condition.	Site visit is scheduled on 24 th October 2021, 11:00 hrs Venue: IGMH (OPD Gate no.1)

اسم

Name: Aishath Nadheema

اسم

Signature:

