

بسم الله الرحمن الرحيم



Ministry of Finance

Ameenee Magu, Male', Republic of Maldives

Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ ޕްރޮގްރެސިވް
މާލެ، ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ

ADDENDUM 2

އަދަދު 2

ނަންބަރު No:	TES/2021/G-014		
ފްރޮޖެކްޓް Project:	Procurement of Design, Supply and Installation of Grid - tied Solar PV-Storage-Diesel Hybrid Power Generation Plants in HA.Hoarafushi under Power Purchasing Agreement.		
އިއުޖިންޑް Issued Date	September 19, 2021		
ސަފުހާގެ އަދަދު No. of Pages: -05	ބޯޕްރިއަންޓް BoQ: -00	ޖަހާލުމުގެ އަދަދު Drawings: -00	

Please include this amendment when submitting the bid. ބިދު ހުށަހަޅާއިރު މި އަދަދު ހިމާނުވާން ޖެހޭނެއެވެ.

Attached with, please find;

- Changes brought to the Tender Document
- Revised Licensing Agreement

ނަންބަރު

Name: Fathimath Rishfa Ahmed

ސަފުހާ

Signature:

[Handwritten Signature]



➤ Section II – Bid Data Sheet

ITT Clause	Tender data that supplements the ITT
ITT 22.1	<p>For Tender <u>submission purposes</u> only, the Employer's address is:</p> <p>Ms.Fathimath Rishfa Ahmed, Chief Procurement Executive, National Tender Ministry of Finance Ameenee Magu, Male', 20379 Republic of Maldives Tel: (960) 334 9125, (960) 334 9106 E-mail: ibrahim.aflah@finance.gov.mv tender@finance.gov.mv</p> <p>Date: 30th September 2021 Time: 1300 hrs (Local Time)</p>
ITT 25.1	<p>The Tender opening shall take place at: Street Address:</p> <p>National Tender Ministry of Finance Ameenee Magu, Male', 20379 Republic of Maldives</p> <p>Date: 30th September 2021 Time: 1300 hrs (Local Time)</p>



Amu

➤ Following changes are brought to the Section VII - Technical Requirements

1	<p>Section VII - Technical Requirements Part D -Solar Farm Connection Requirements D.3 11KV CONNECTIONS</p>	<p>D.3. 11kV connections</p> <p>Each 11-kV connection will be provided with a ground based outdoor ring main unit (RMU) consisting of two isolators, feeder circuit breaker earth switch, metering, protection and control interfaces.</p> <p>Solar PV generation will be converted from DC to LV AC, at voltage selectable by the Contractor appropriate to the selected inverter type (but not more than 1,500 V). As Maldives commonly operates at 400 V for LV systems, 400 V should be used where it is an option without cost impact. LV feeders will feed to a single step up transformer sized to accommodate maximum generation output, and any harmonic loads.</p>
---	---	---



Handwritten signature in blue ink.

➤ Following changes are brought to the Section III - Evaluation and Qualification Criteria

1. Technical Evaluation

In addition to the criteria listed in ITB 35.1 – the following criteria shall apply

Assessment of adequacy of Technical Proposal with Requirements

Bidders submitted Technical Proposal will be assessed against Section VII - Technical Requirements.

TECH FORM-1

- Minimum Capacity of at least **2 MWp** total: (PASS / FAIL Criteria)

TECH FORMS-2 to 13 and Form PER – 1 to 2

- To be submitted completely and to comply with minimum technical requirements.

Eligibility and Qualification Criteria			Compliance Requirements			Documentation
No	Subject	Requirement	Single Entity	Joint Venture (existing or intended)	Submission Requirements	
4.1 (a)	General Construction Experience	A minimum number of TWO completed construction contracts and a cumulative experience of 2 MWp grid connected solar PV projects (floating /ground-mounted/rooftop) in the role of prime contractor, JV member, Subcontractor, or management	Must meet requirement	<div> <div>All Members Combined</div> <div>Must meet requirement</div> </div> <div> <div>Each Member</div> <div>N/A</div> </div> <div> <div>One Member</div> <div>At least 50 % of the cumulative experience requirement of 2MW</div> </div>	Form EXP – 4.1	

[Handwritten signature]

		contractor between 1st January 2015 and Bid submission.					
4.2 (a)	Specific Experience - Developing Projects	A minimum number of TWO completed construction contracts and a cumulative experience of 100 kWp floating solar PV in a marine environment similar in nature to the proposed installation site in the role of prime contractor, JV member, Subcontractor, or management contractor between 1st January 2015 and Bid submission.	Must meet requirement	N/A	N/A	Must meet requirement	Form EXP – 4.1

Delete the following:

Section III – Evaluation and Qualification Criteria D. Qualification 6. Equipment	“Section III, D, 6”: Deleted.
---	-------------------------------

----- End of Document -----



Handwritten signature