BUILDING SERVICES DRAWINGS OF

PROPOSED 03 STOREY

MULTI PURPOSE HALL AND EIGHT CLASSROOM BLOCK, SH.FEYDHOO

For Ministry Of Education

By Epoch Associates Pvt. Ltd



± 13A Twin Socket ± 13A Power Socket

Distribution Board HL. High Level

Computer Network Outlet

Emergency LightW3 Wall Mounted Speaker

M Electricity Meter

Public Address System

Computer Network Twin Outlet


HDMI Socket

Ceiling Mounted Exhaust Fan 90m3/hr

Main Incoming Cable For Power PVC Duct Below Ground82Ø PVC Duct For Internet Cables Lead In Below Ground Slab

Notes: -

- All Twin Sockets At 300mm From F.F.L. Except Stated Otherwise
- All Computer, Telephone Points At 300mm From F.F.L. - All electrical components shall be connected to respective
- All electrical components shall be connected to respective Distribution Box in the same area as the component.
- All electrical components in common areas, corridors and staircase should be connected to Common Area DB
- Wall Speaker shall be connected to Public address system of school



BLOCK,
SH. FEYDHOO

Client:
Ministry Of Education

February 2021

Services By: Mohamed Rassam
Checked By:
Drawn By: Hussain Rasheed

Fr. +960 333 3528 F. info@epoch.associates
W: www.epoch.associates, A.G.Rosary West,
Husnuheenaa Magu, Male' Republic of Maldives

Rev:
Rev:
Page:
PAC-01

PROPOSED 03 STOREY

MULTIPURPOSE

HALL AND EIGHT

CLASSROOM

13A Twin Socket 13A Power Socket Distribution Board

High Level

Computer Network Outlet

Emergency Light

Wall Mounted Speaker

М Electricity Meter

Public Address System


Computer Network Twin Outlet


HDMI Socket

Ceiling Mounted Exhaust Fan 90m3/hr

Main Incoming Cable For Power PVC Duct Below Ground 82Ø PVC Duct For Internet Cables Lead In Below Ground Slab

- Notes: All Twin Sockets At 300mm From F.F.L. Except Stated Otherwise
 All Computer, Telephone Points At 300mm From F.F.L.
- All electrical components shall be connected to respective
- Distribution Box in the same area as the component.
- All electrical components in common areas, corridors and staircase should be connected to Common Area DB
- Wall Speaker shall be connected to Public address system of school





□ 13A Twin Socket
□ 13A Power Socket
□ 15A Switched Socket @ H.L.

Distribution Board
HL. High Level

Computer Network Outlet
Emergency Light
WS Wall Mounted Speaker

M Electricity Meter

Public Address System

Computer Network Twin Outlet


HDMI Socket


Ceiling Mounted Exhaust Fan 90m3/hr

Main Incoming Cable For Power PVC Duct Below Ground82Ø PVC Duct For Internet Cables Lead In Below Ground Slab

Notes: -

- All Twin Sockets At 300mm From F.F.L. Except Stated Otherwise
- All Computer, Telephone Points At 300mm From F.F.L.
- All electrical components shall be connected to respective
- Distribution Box in the same area as the component.
 All electrical components in common areas, corridors and staircase
- All electrical components in common areas, corridors and sta should be connected to Common Area DB
- Wall Speaker shall be connected to Public address system of school





CO₂ Extinguisher (load: 2kg) In Polycarbonate Enclosure DCP Extinguisher (load: 6kg) In Polycarbonate Enclosure

H₂O Extinguisher (load: 9L) In Polycarbonate Enclosure

Manual Call Point (At 1200mm from F.F.L.)

(SD) Smoke Detector

Beacon


Sounder Bell


2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Running Underground)

2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Above False Ceiling or Through Slab)

FACP Fire Alarm Control Panel

EXIT Exit Sign





CO₂ Extinguisher (load: 2kg) In Polycarbonate Enclosure DCP Extinguisher (load: 6kg) In Polycarbonate Enclosure

H₂O Extinguisher (load: 9L) In Polycarbonate Enclosure

Manual Call Point (At 1200mm from F.F.L.)

(SD)

Smoke Detector


Beacon


Sounder Bell

2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Running Underground) 2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Above False Ceiling or Through Slab)

FACP Fire Alarm Control Panel

EXIT Exit Sign





CO₂ Extinguisher (load: 2kg) In Polycarbonate Enclosure

DCP Extinguisher (load: 6kg) In Polycarbonate Enclosure

H₂O Extinguisher (load: 9L) In Polycarbonate Enclosure

Manual Call Point (At 1200mm from F.F.L.)

(SD) Smoke Detector

Beacon

Sounder Bell


2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Running Underground)

2.5mm² Fire Retardant Low Smoke (FRLS) Cables In FRLS Conduits (Above False Ceiling or Through Slab)

FACP Fire Alarm Control Panel

EXIT Exit Sign





Ceiling Light (18W)

Ceiling Light (12W)

Recessed Ceiling Light (12W)
 Ceiling Down Light (19W) W

Ceiling Down Light (18W) - Weather Proof Weather Proof Wall Light IP55 (12W)

3 Ft Led Tube Light


2 x 50W PLL Tube Light

12345 Light and Fan Switch (1 Gang - 5 Gang)



42" To 48" Ceiling Fan

Ceiling Mounted Exhaust Fan 90m3/hr



PROPOSED 03 STOREY

MULTIPURPOSE

Ceiling Light (18W)
Ceiling Light (12W)

Recessed Ceiling Light (12W)

O Ceiling Down Light (18W) - Weather Proof Weather Proof Wall Light IP55 (12W)

3 Ft Led Tube Light


2 x 50W PLL Tube Light


12345 Light and Fan Switch (1 Gang - 5 Gang)



42" To 48" Ceiling Fan

Ceiling Mounted Exhaust Fan 90m3/hr





Ceiling Light (18W)
Ceiling Light (12W)

Recessed Ceiling Light (12W)

Ceiling Down Light (18W) - Weather Proof
Weather Proof Wall Light IP55 (12W)

3 Ft Led Tube Light


2 x 50W PLL Tube Light


1121314151 Light and Fan Switch (1 Gang - 5 Gang)



42" To 48" Ceiling Fan

Ceiling Mounted Exhaust Fan 90m3/hr





16Ø Cold Water Supply To Basin Faucet
16Ø Cold Water Supply To Bidet Shower
16Ø Cold Water Supply To Cistern
Gate Valve

Rise In Wall

Ø Drop In Wall

Angle Valve with cap for Ground Water Supply
25Ø Cold Water Supply Pipes Running Underground
20Ø Cold Water Supply Pipes Running In Wall


20Ø Cold Water Supply Pipes Running Above False Ceiling

20Ø Cold Water Supply Pipes Running Underground


25Ø Ground Water Supply Pipes

Notes: -

-All Cold Water Pipes Should Be PVC -SII Hot Water Pipes Should Be PPR



GROUND FLOOR PLUMBING LAYOUT



.....


Legend

16Ø Cold Water Supply To Basin Faucet
16Ø Cold Water Supply To Bidet Shower
16Ø Cold Water Supply To Cistern
Gate Valve
Rise In Wall
Drop In Wall
Angle Valve with cap for Ground Water Supply
25Ø Cold Water Supply Pipes Running Underground
20Ø Cold Water Supply Pipes Running In Wall
20Ø Cold Water Supply Pipes Running Above False Ceiling
20Ø Cold Water Supply Pipes Running Underground

25Ø Ground Water Supply Pipes

Notes: -

-All Cold Water Pipes Should Be PVC -SII Hot Water Pipes Should Be PPR



FIRST FLOOR PLUMBING LAYOUT

February 2021

Services By: Mohamed Rassam Checked By: Drawn By: Hussain Rasheed

T: +960 333 3528 E: info@epoch.associates W: wwww.epoch.associates A:G.Rosary West, Husnuheenaa Magu, Male' Republic of Maldives

Rev: Page: PL -02

PROPOSED 03 STOREY

MULTIPURPOSE

16Ø Cold Water Supply To Basin Faucet
16Ø Cold Water Supply To Bidet Shower
16Ø Cold Water Supply To Cistern
Gate Valve
Rise In Wall

Rise In WallDrop In Wall


Angle Valve with cap for Ground Water Supply
25Ø Cold Water Supply Pipes Running Underground
20Ø Cold Water Supply Pipes Running In Wall

20Ø Cold Water Supply Pipes Running Above False Ceiling 20Ø Cold Water Supply Pipes Running Underground

25Ø Ground Water Supply Pipes

Notes: -

-All Cold Water Pipes Should Be PVC -SII Hot Water Pipes Should Be PPR



MULTIPURPOSE
HALL AND EIGHT
CLASSROOM
BLOCK,
SH. FEYDHOO
Client:
Ministry Of Education

February 2021

Services By: Mohamed Rassam
Checked By:
Drawn By: Hussain Rasheed

T: +960 333 3528 E: info@epoch.associates
W: wwww.epoch.associates, A:G.Rosary West,
Husnuheenaa Magu, Male' Republic of Maldives

Rev: Page:
PL -03



Floor Drain
Floor Gully
110Ø Soil Pip

⇒ 110Ø Soil Pipe (uPVC Pipe)
⇒ 110Ø Soil Vent Pipe (uPVC Pipe)

82Ø Waste Pipe (uPVC Pipe)
82Ø Waste Vent Pipe (uPVC Pipe)

40Ø Waste Pipe (uPVC Pipe)
63Ø Manhole Vent Pipe (uPVC Pipe)
110Ø Rain Water Pipes (uPVC Pipe)

Clean Out Point


Bottle Trap

Manhole

Gully Trap

Notes: -

-All Drainage Pipes Should Have At A Slope Of 1/150 -All Floor Drains Should Have 'P' Traps



GROUND FLOOR DRAINAGE LAYOUT


MULTIPURPOSE
HALL AND EIGHT
CLASSROOM
BLOCK,
SH. FEYDHOO
Client:
Ministry Of Education

February 2021


Services By: Mohamed Rassam
Checked By:
Drawn By: Hussain Rasheed

Fr: +960 333 3528 .E: info@epoch.associates
W: www.epoch.associates, A.G.Rosary West,
Husnuheenaa Magu, Male' Republic of Maldives

Rev: Page:
DR -01



LegendFloor DrainFloor Gully





Floor Drain Floor Gully

→ 110Ø Soil Pipe (uPVC Pipe)

▶ 110Ø Soil Vent Pipe (uPVC Pipe) → 82Ø Waste Pipe (uPVC Pipe)

82Ø Waste Vent Pipe (uPVC Pipe)

40Ø Waste Pipe (uPVC Pipe)

→ 63Ø Manhole Vent Pipe (uPVC Pipe)


110Ø Rain Water Pipes (uPVC Pipe)


Clean Out Point


⊸ Bottle Trap

Manhole

Gully Trap







Bottle Trap

Manhole

Gully Trap

