



## ADDENDUM 01

ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ Project No:	TES/2017/W-035
ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ Issued Date:	December 24, 2017
ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ Project:	Provision of Water Supply Facilities in B.Dharavandhoo
ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ Deadline for submission:	Monday, January 8, 2017 at 1100 hours
ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ No. of Pages: - 02	Boq: -01      Drawings: -01

Please include this addendum when submitting the proposal

1. Clarification 01 is enclosed with this addendum
2. Revised BOQ and Drawings are uploaded to the website, [www.finance.gov.mv](http://www.finance.gov.mv)

+

The **Bid Submission** for the project will be held on **Monday, 8<sup>th</sup> January 2017, 11:00hrs**  
at National Tender / Ministry of Finance and Treasury (5<sup>th</sup> floor, Treasury building)

ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ  
Name: Aminath Naheen Ahmed

ދިވެހިރާއްޖޭގެ ޖުމްހޫރިއްޔާ ގެ ފުނަންޝިއަލް ޖެނެރަލް ޖަވާބު ދާއިރާ  
Signature:





Ministry of Finance and Treasury

Male' Republic of Maldives

### Provision of Water Supply Facilities in B.Dharavandhoo

#### Clarification 01

No.	Query	Answer
01	Tender documents are silent about drawings of following <ul style="list-style-type: none"><li>• Raw Water Tanks (RTP) Foundation Details</li><li>• Clear Water tanks (RTP) foundation Details</li><li>• Slow Sand Filter</li><li>• Bore / Tube Well</li><li>• Rain Water Lift Well</li><li>• Brine Disposal</li></ul>	1. Detail drawings (foundations, wells, brine disposal line) are now included in final document. 2. Slow Sand filter replaced with Ultrafiltration system.
02	Please Clarify Beneficiary Name and Address (Required for Bonds and Credit facilities)	Ministry of Finance and Treasury Ameenee Magu, Male', 20-03 Republic of Maldives,
03	There is no Specification for R. Maduvvaree Islands.	Submitted. Please re-check
04	Please Confirm the sizes of RAW water tank and Clear water tank. Because sizes are different in BOQ and Drawing in R. Maduvvaree Islands	Please consider 600cum for Raw water Tank and 400cum for Clear Water tank (Values now revised in BOQ).
06	There are no Pricing Preambles for B. Dharavandhoo, Hdh. Nolvivaranfaru, R. Maduvvaree	Preambles for all 4 islands (Sh.Foakaidhoo, Ba.Dharavandhoo, R.Maduvvaree, HDH.Nolvivaranfaru) are same. Hence, please use preamble given for Sh.Foakaidhoo for the other three Islands.
7	<b>B.Dharavandhoo</b> - BOQ duration for this project its 18 months, but in tender document its 12 months.	Please consider 12 months duration as per BOQ
	- BOQ Bill no: III, length is different	Please consider length under "Quantity" Column
8	<b>Maduvvaree, Nolvivaranfaru, Foakidhoo</b> BOQ duration for this project its 18 months, but in tender document its 12 months.	Please consider 12 months duration as per BOQ
	BOQ bill No: VIII, QTY is missing.	Qty is mentioned in the below row, as a whole item
9	Conversion rate from USD to MVR.	Refer to Section 2, Bid Data, ITB 32.1

