



**CLARIFICATION 1**

1 ވަނަ ބަޔާންކުރުމުގެ ސަބަބުން

ނަންބަރު <b>No:</b>	<b>TES/2021/ W-143</b>		
ފުރިހަމަކުރަންޖެހޭ <b>Project:</b>	<b>Construction of Hdh.Neykurendhoo Industrial Prison Boundary wall</b>		
ފޮނުވާލެވިފައިވާ <b>Issued Date</b>	<b>06<sup>th</sup> October 2021</b>		
ސަފުޙާގެ އަދަދު <b>No. of Pages: -1</b>	ބޯޕްލާނު <b>BoQ: -00</b>	ވަނަވަނަ <b>Drawings: -00</b>	

Please include this amendment when submitting the bid

➤ Please find the answer of the query.

Question	Answers
<p>1. BOQ Serial No.12 (wall length is 669 mtr, Height is 3mtr) total 2007 SQM. Although drawing wall section details the wall height as 6 mtr and BOQ all the sqmeter, calculating 3mtr. Please clarify.</p>	<p>It is calculated the length by 3 m because the wall height is divided into two. One above the mid beam &amp; one below the mid beam with different thickness in the wall as provided in the BOQ.</p>



ނަންބަރު  
**Name: Fathimath Rishfa Ahmed**

ސަފްޞާޙާ  
**Signature:**