



Ministry of Finance

Project Name: Supply and Installation of 25-ton Ice plants in Ha. Dhidhdhoo, Sh. Komandoo, Aa. Rasdhoo, Dh. Meedhoo and L. Maamendhoo, Maldives

Project Number: TES/2021/G-017

CLARIFICATION 1

Question	Answer
<p>(a) Participation in at least two contracts that have been successfully or substantially completed within the last 5 years and that are similar to the proposed contract, where the value of the Bidder's participation exceeds MVR USD 467,000 per contract. The similarity of the Bidder's participation shall be based on the physical size, nature of works, complexity, methods, technology or other characteristics as described in Employer's Requirements.</p> <p>(b) For the above or other contracts executed during the period stipulated in 2.4.2 above, a minimum experience in the following key activities:</p> <p>(i) Supply and Installation of ice plant or related activities</p> <p>(ii) Civil works</p> <p>Question is that whether you consider the "cold storage work" as related work. Or civil works can be considered as related work too</p>	<p>Cold storage work will be considered as related work. Civil works is not considered a related work but it is another requirement</p>
<p>What exact documents are required to submit for manufactures authorization</p>	<p>A document issued by the manufacturer on their official letterhead indicating that the bidder is authorized/certified to install the equipment developed by the manufacturer</p>
<p>Couldn't find ITT 4.3, ITT 4.5 and ITT 29.1</p>	<p>Refer to ITT Clause 4.3, ITT Clause 4.5 and ITT clause 29.1 in the issued Bidding Document</p>
<p>Page 219, Couldn't find any ITB points</p>	<p>Page number 219 does not exist in the Bidding Document</p>
<p>What would be the space for the unit</p>	<p>A land area of 2000sqft (minimum) will be allocated for the site. Other requirements are provided in the technical specification</p>
<p>How big are the boats, the measurements for the space fish is stored or the volume of the water tanks</p>	<p>The sizes of the boats may range from 75ft to 100ft. The dimensions of the boats and the fish holds will vary from boat to boat.</p>
<p>Is there any requirements for water flow rate</p>	<p>No. This should be assessed and decided by the bidder. The technical specification will provide the requirements for cooling the fish</p>
<p>Under the chiller requirements, it's written it should be Titanium Shell and tubes, is it for both the evaporator and condenser or can the evaporator be titanium, and the condenser be of copper/nickel.</p>	<p>The chiller/evaporator unit should be Titanium. The Condenser can be made of copper/nickel.</p>

