بسم الله الرحمن الرحيم

Ministry of Finance and Planning
Ameenee Magu, Male', Republic of Maldives
Telephone: (960) 334 9266, Fax: (960) 332 0706

މިނިސްޓްރީ އޮފް ފިނޭންސް އެންޑް ޕްލޭނިންގ
އަމީނީމަގު، މާލެ، ދިވެހިރާއްޖެ

CLARIFICATION 1 ކްލެރިފިކޭޝަން 1

ނަންބަރު **No:**	**TES/2025/W-155**		
ޕްރޮޖެކްޓް Project:	**Remaining works of R. Inguraidhoo New Health Center Building**		
ތާރީޚު Issued Date	**8th December 2025**		
ސަފުހާގެ އަދަދު No. of Pages: -01	ބީ.އޯ.ކިއު BoQ: -00	ޑްރޯއިންގ Drawings: -00	

Please include this amendment when submitting the bid ބީޑު ހުށަހަޅުއްވާއިރު މި ގަނޑުފަތް ޒިޔާދަކޮށްގެން އެކު ހުށަހަޅުއްވުން ދަންނަވަމެވެ.

- **Please find below the response to the queries raised.**

Contractor Comment	Response/Reference Document
1. BOQ item 15.2.10 quantity stated in blank since the cable can be visible in the drawing. Is this either a BOQ error or not included in this scope?	It is an itemized provision, the bidder should price for full length of cable required as a lump sum under the provision. The contractor to determine the quantity of cable needed. To leave item as quantity 1
2. BOQ item 14.10.00 Air Condition and Ventilation The insulation quantity of the AC and ventilation in the BOQ is in blank status. However, the other parts that are required for the AC and ventilation are covered in the given BOQ. Please clarify whether this is an error in the boq or it's not included in this scope?	The BOQ provision is for full functioning air condition and ventilation units supply and installation including insulation and other connection material. The price to be submitted accordingly
3. The drawing of the medical gas for the captioned building service is not included in the tender document set. we kindly request to provide the drawing.	As per BoQ item 17.2, the contractor is responsible for the design, supply, and complete installation of the oxygen delivery system. The design of the oxygen plant should be submitted for MoH approval prior to installation. Please note that no additional charges could be claimed for the component post contract.
4. The medical vacuum system was not included as a scope in the BOQ. However, it has mentioned in the BOQ note. Please clarify?	BOQ 17.2 requires a full itemized cost for all the described systems in the required rooms. Please price accordingly for all the items.
5. We are requesting a 1week extension	**Refer to Addendum 4**
6. we are requesting 10 days extension	

ނަން **Name: Fathimath Rishfa Ahmed**	ސޮއި **Signature:**

MINISTRY OF FINANCE AND PLANNING
Male', Republic of Maldives