

NINE STOREY AIR CONDITIONING

- 3-phase to be provided to the outdoor units.
- There should be a control Network system connecting indoor and outdoor units and between centralised control system and I/O units through H-LinkII
- Internal Data and fault diagnosis should be easily accessed by user through CS-NET and there should be a central station DX to access the network.
- In the extreme condition of 32 Deg Celcius and 80% RH, there is tendency of condensation on pipe surfaces. Therefore refrigerent pipe insulation thickness should be more than 30mm and sould be aluminium foiled to prevent condensation on the sursafe of the pipe. (*recommended brand of insulation **thermal flex***)
- Recommended AC brand is HITACHI.