



三



MINIMUM 50MM COVER BELOW GROUND LEVEL	ALL BAR BENDING & OVERLAPS AS PER ACTUAL BS STANDARD
MINIMUM 50MM COVER ABOVE GROUND LEVEL	

NOTE:
LINTEL BEAMS TO BE LAID ABOVE ALL
DOORS, WINDOWS AND VENTILATORS.
SILL BEAMS TO BE LAID BELOW ALL
WINDOWS AND VENTILATORS.

SHEET CONTENTS :	

REVISION NOTES:	

PROJECT:	
CONSTRUCTION OF 6	
PRIVATE ROOM AT R.	
UNGODFAARU REGIONAL	
HOSPITAL	
CLIENT:	
MINISTRY OF HEALTH	
LOCATION:	
R. UNGODFAARU	
CONTENTS: AS GIVEN	
PROJECT MANAGER:	
DESIGNER: ARIZ	
CIV/STR. ENGINEER:	
SUPERVIEWED BY: -	
DRAWN BY: ARIZ	
CHECKED BY:	
DATE : FEBRUARY 2017	
SHEET NO. : /	



*ADMIN DIVISON
Ministry of Health
Roshanee Building
Sosun Magu'
Tel: 332 8887, Fax: 3328889*