
تب ما مندازهمن أرحيهم



ورسائير برو ويرس

CLARIFICATION 2

ر و برور سوسو سور 2

سَرُسُوْهُ ر No:	TES/2020/W-004	
Project:	Design and Build of 36 Housing Units and Completion of 64 Housing Units at Th. Vilufushi	
ار العام Issued Date	16 th March 2020	
بَـُوْرُدُوْ مُـُوَرُوْ No. of Pages: -1	3y.3.g BoQ: -00	Drawings: -00

- Below please find the clarifications for the queries
- 1. Refer to clarification 1, point no. 11 "utilities main connection such as water, sewer, and electrical main to be included in this contract connection of utilities (electricity, water and sewerage) up to the main lines shall be included for each individual unit." We have checked the site and found that still there is no sewerage and electrical network for the 64 housing unit areas and allocated land for 36 housing units. Council has mentioned that they need to check whether the capacity of the existing networks would be sufficient to cater to this new requirement. Therefore please confirm

Provisions of connection of utilities (electricity, water & Sewerage) up to the main lines shall be included for each individual unit. Connections to main lines are not in the scope of the contractor

2. We have noticed the free space around each building (64 housing units) will not be sufficient to place the rain water tank. Therefore please confirm whether this can be placed in multipurpose area which is located at the front side of each unit

Can be placed

3. Since conduit works has been completed for some existing housing units is it possible to provide the existing services layout

Service layout is unavailable. Contractor is required to prepare service drawings.

Name: Aishath Nadheema

سرير

Signature:

