



1. ALL DIMENSIONS ARE IN mm EXCEPT AND OTHERWISE SPECIFIED.
2. THIS DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT DRAWINGS AND SPECIFICATIONS.
3. ALL ABOVE GROUND CONDUIT SHALL BE RIGID HOT DIP GALVANIZED EXCEPT AS NOTED.
4. ALL NEMA 3R GASKETED 9.5 ENCLOSURES TO HAVE LOCKABLE HANDLE AND 3 POINT LATCHING.

#### LEGENDS

TYPE	SYMBOL	DESCRIPTION
B		1 x 40W SURFACE MOUNTED FLUORESCENT LIGHT FITTING
C		1 x 40W WALL MOUNTED FLUORESCENT LIGHT FITTING-WEATHERPROOF
FE		1 x 60W SURFACE MOUNTED FLUORESCENT DOWN LIGHT - WEATHERPROOF
		5A SWITCHED SOCKET OUTLET (1.000W)
		5A SWITCHED SOCKET OUTLET AT HEIGHT LEVEL-WEATHER PROOF (1.000W)
		1.3A TWIN SWITCHED SOCKET OUTLET
		JUNCTION BOX
		20A DP SWITCH
		EXHAUST FAN (80W)
		TELEPHONE TERMINAL BOX
		SINGLE OUTLET FOR DATA
		SINGLE OUTLET FOR VOICE
		0.6x0.6m HAND HOLE

#### REFERENCE DRAWINGS

SL No.	DRAWING No.	DESCRIPTION

..	..	..	..	..	..
..	..	..	..	..	..
..	..	..	..	..	..
..	..	..	..	..	..

REV.	DATE	DESCRIPTION	DRAWN	CHKD.	APPRD.
0	17-09-15	DETAILED DESIGN SUBMISSION	BA	RDS	MA

#### REVISION

CLIENT
MINISTRY OF ENVIRONMENT & ENERGY REPUBLIC OF MALDIVES

CONSULTANT:
مكتب الحبشي للاستشارات الهندسية Al-Habshi Consultants Office Tel.: 2430103 / 2433131 - Fax: 2431136 P.O.Box 27154 Safat 13132 - Kuwait

PROJECT:
Provision of Water Supply Facilities in 04 islands and Sewerage Facilities in 05 islands - N.Velidhoo Island - Republic of Maldives

DRAWING TITLE:
RO PLANT ADMIN BUILDING ELECTRICAL LAYOUT N.VELIDHOO ISLAND

DESIGNED	DRAWN	CHECKED	APPROVED	SCALE	DATE
RDS	BA	RDS	MA	1 : 50	17-09-15

PROJECT No.	SHEET No.	DRAWING No.
K-619	1 OF 1	NV-EL-105

REV. No.	0
----------	---