



جِسْمِ سَمْعِ بِرَزَقِ وَتَرْسَمِ
رَدِ سَمْعِ، رُخ، مَرَقِ سَمْعِ

[illegible]

No:	TES/2019/W-13		
Project:	Construction of Bahaahudheen Magu at S.Hulhumeedhoo		
Issued Date	20 th March 2019		
No. of Pages: - 01	Boq: - 00	Drawings: - 00	

Please include this amendment when submitting the bid. بموجب هذا التعديل

7. We would like you to identify us the borrow areas for material which would be required to complete the works mentioned below: (common for all 8 island)
For the BOQ, under CARRIAGEWAY bill it has been mentioned: Cut, fill, shape the sub-grade and compact to get the specified cross elevation and required CBR for the subgrade.

Please refer to the EIA reports approved by EPA.

2. For green area of carriageway under kerb stone a concrete beam has been shown in the concept drawings. Please advise how to incorporate this work in BOQ. Is it going to be an (addition under ADDITIONS AND / OR OMISSIONS) or should we add this work as a separate item under bill SIDE WALK?

Please refer to BoQ Item 3.2.1 (Hdh.Hanimaadhoo), it states “Rates shall include casting, curing and placing of curbstone. Rates shall also include dry mix layer/ lean below curbstone”.

Signature:

